



## City of Circleville

### Local Industrial User Limits

The City of Circleville has the authority to develop, implement, and enforce local limits in the industrial users' Industrial Wastewater Permit to ensure that the total pollutant loading from industrial sources do not exceed the following:

| <b>Pollutant of Concern</b>   | <b>Local Limit (lbs/day)</b> |
|-------------------------------|------------------------------|
| Arsenic                       | 1.41                         |
| Cadmium                       | 1.33                         |
| Total Chromium                | 20.00                        |
| Dissolved Hexavalent Chromium | 0.86                         |
| Copper                        | 2.67                         |
| Free Cyanide                  | 2.01                         |
| Lead                          | 15.26                        |
| Mercury                       | 0.0009                       |
| Molybdenum                    | 30.86                        |
| Nickel                        | 6.16                         |
| Selenium                      | 3.89                         |
| Silver                        | 1.08                         |
| Zinc                          | 1.54                         |
| Ammonia Nitrogen              | 835.0                        |
| 5 day CBOD                    | 6234.0                       |
| TSS                           | 6807.0                       |

This total industrial loading limit was approved by the Ohio EPA on 5/11/21.